



Government of India
Ministry of Commerce & Industry
Petroleum & Explosives Safety Organisation (PESO)
5th Floor, A-Block, CGO Complex, Seminary Hills,
Nagpur - 440006

E-mail : explosives@explosives.gov.in
Phone/Fax No : 0712 -2510248, Fax-2510577

Approval No : A/P/HQ/MH/104/8256 (P602546)

Dated : 29/10/2024

To,

M/s. Micro Pneumatics Pvt. Ltd.,
GutNo.,
Vasai Municipal Industrial Area, Vasai West,
Palghar,
Taluka: Palghar,
District: PALGHAR,
State: Maharashtra,
PIN: 401207

Sub : Approval of Flame Proof Type Electrical Equipments under Petroleum Rules 2002. under Petroleum Rules 2002- Regarding.

Sir(s),

Please refer to your letter No. **OIN1787405** dated **07/10/2024** on the subject.

The following Ex electrical equipment(s) manufactured by you according to **IS/IEC 60079-1 : 2014**, standards and covered under **ELCA LABORATORIES** Test reports mentioned below is/are approved for use in **Zone 1, Zone 2** of Gas **IIC** hazardous areas coming under the the Petroleum Rules, 2002 administered by this Organization.

Sr. No	Description	Safety Protection	Equipment reference Number	Test Agency			Drawing no
				Name	Certificate No.	Certificate Date	
1	Flame Proof Cum Weather Proof Limit Switch 2M Model No: MP-PI-2M-FP	Ex d IIC T6 Gb	P602546/1	ELCA LABORATORIES	E-4234-M-1 & 2	27/03/2023	MP-PI-2M-FP-02 SHEET 1 OF 2 AND 2 OF 2

This Approval is granted subject to observance of the following conditions:-

- 1) The design and construction of the equipment shall be strictly in accordance with description, condition and drawings as mentioned in the Test Reports referred to above.
- 2) The equipment shall be used only with approved type of accessories and associated apparatus.
- 3) Each equipment shall be marked either by raised lettering cast integrally or by plate attached permanently to the main structure to indicate conspicuously:-
 - (a) Name of the manufacturer
 - (b) Name and number by which the equipment is identified.
 - (c) Number & date of the test report of the ELCA LABORATORIES applicable to the equipment.
 - (d) Equipment reference number of this letter by which use of apparatus is approved.
 - (e) BIS approval number.
 - (f) Protection level.
- 4) A certificate to the effect that the equipment has been manufactured strictly in accordance with the drawing referred to in the Test report and is identical with the one tested and certified at Testing agency shall be furnished with each equipment.
- 5) The customer shall be supplied with a copy of this letter, an extract of the conditions and maintenance schedule, if any, recommended by ELCA LABORATORIES and copy of instructions booklet detailing operation & maintenance of the equipment so as to maintain its safe characteristics.
- 6) The IS/IEC 60079-17 and IS/IEC 60079-19 shall be followed for maintenance and repair of overhaul of the subject equipments.

Conditions of the Approval:-

The approval for the above electrical equipment is subject to the validity of the BIS License, which shall be renewed periodically after expiry. The special conditions of use given in the ELCA test report shall be duly taken care of at all times.

This approval also covers the permissible variations as approved under the ELCA LABORATORIES test reports referred above. This approval is liable to be cancelled if any of the conditions of the approval is violated or not complied with. The approval may also be amended or withdrawn at any time, if considered necessary in the interest of safety.

The field performance report from actual users/your customers of the subject equipment may please be collected and furnished to this office for verification and record on annual basis. The Approval is Valid upto **31/12/2026**

Yours faithfully,

(Kanak Singh Meena)
Dy. Controller of Explosives
For Chief Controller of Explosives
Nagpur

Copy to :

1. Jt. Chief Controller of Explosives, West Circle, MUMBAI

for Chief Controller of Explosives
Nagpur

(For more information regarding status, fees and other details please visit our website <http://peso.gov.in>)

This is System Generated document. Signature is not required.